CHECKLIST (to be completed by site manager/supervisor)

Com	pany:				
Site:					
Plot:		Site manager/supervisor:			
Ref.	Item		Ye (✔	s No	Inspected (initials & date)
1.	Is separating wall cavity at least 75mm?				· · · · · · · · · · · · · · · · · · ·
2.	Is external (flanking) wall cavity at least 50mm?				
3.	Are separating wall blocks Besblock Star Performer 5-bridge cellular blocks?				
4.	Are the blocks laid with the cells open to the lower bed?				
5.	Is cavity free from droppings and debris?				
6.	Are separating wall ties Approved Document E "Tie type A" (see appendix A)?				
7.	Are cavity stops installed?				
8.	Are joints fully filled?				
9.	Are voids around floor joists, chases, etc. fully filled/sealed?		?		
10.		ed to the whole wall face (except where ween floor joists/beams)?	e it		
11.		parating floor (e.g. flats/apartments) has strip been installed?	S		
12.	Are all junctions of or caulked with sea	wall and ceiling boards sealed with tape lant?	•		
13.	Is separating wall sa	atisfactorily complete?			
	ntact details for technical	assistance from Besblock, manufacturer of 'Sta Fax: 01952 585224 E-mail:	ar Performe		
		f any corrective action)			
Sit	e manager/superviso	or signature			

Warning: the doing of an unauthorised act in relation to a copyright work may result in both a civil claim for damages and criminal prosecution.

[®] UK registered trade mark no. 2291665

[©] Robust Details Limited 2011. All rights reserved. No part of this Handbook (other than the checklists) may be reproduced in any material form or issued or communicated to the public (including photocopying or storing it in any medium by electronic means, and whether or not transiently or incidentally to some other use of this Handbook) without the prior written permission of Robust Details Limited except in accordance with the provisions of the Copyright, Designs and Patents Act 1988.