E-WM-9

CHECKLIST (to be completed by site manager/supervisor)

Com	ipany:				
Site:					
Plot:		Site manager/supervisor:			
Ref.	Item		Yes (✔)	No (✔)	Inspected (initials & date)
-	Are separating wall blocks dense aggregate (1850 to 2300 kg/m ³) as featured on the list of acceptable blocks (www.robustdetails.com)?				(
2.	Are blocks laid for the full 215mm width of the wall (i.e. 215mm blocks laid on side)?				
3.	Is blockwork laid single course stretcher bond?				
4.	Is separating wall breaking the continuity of the inner leaf? (i.e. is the face of the separating wall abutted and tied or bonded into the inner leaf)				
5.	Are cavity stops inst	alled?			
6 .	Are all joints fully filled?				
7.		er applied to the whole wall face? / be omitted between floor joists/beams)			
3.	Is cement:sand rend finished?	er at least 13mm thick and scratch			
).	ls mass per unit area 12.5 kg/m²?	a of the gypsum based board at least			
10.	Are all junctions of v or caulked with seal	vall and ceiling boards sealed with tape ant?			
11.	Is separating wall sa	tisfactorily complete?			
Not	t es (include details of	any corrective action)			
Sito	manager/supervisor	signature			

® UK registered trade mark no. 2291665

© Robust Details Limited 2011. All rights reserved. No part of this Handbook (other than the checklists) may be reproduced in any material form or issued or communicated to the public (including photocopying or storing it in any medium by electronic means, and whether or not transiently or incidentally to some other use of this Handbook) without the prior written permission of Robust Details Limited except in accordance with the provisions of the Copyright, Designs and Patents Act 1988.

Warning: the doing of an unauthorised act in relation to a copyright work may result in both a civil claim for damages and criminal prosecution.